



Forbo Giubiasco SA
Report No. FO 1702-889

Cleanroom[®] Suitable Materials

Colorex SD
(smooth)
Riboflavin test: excellent

FLOORING & COATING

Riboflavin Test

Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

Forbo Giubiasco SA
Giubiasco, Switzerland

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number FO 1702-889.

Based on the VDMA information sheet »Riboflavin test for low-germ or sterile process technologies«, the ability to remove the fluorescent test contamination from the surface was tested by using a simple wiping process and ultra-pure water.

The examination of cleanability of Colorex SD (color: everest) was investigated according to VDMA information test sheet. The following test result could be provided:

Material tested	Classification
Colorex SD (smooth)	excellent

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

FO 1702-889
Report No. first document
--
Report No. current document

Stuttgart, August 10, 2017
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.