



Roche Diagnostics GmbH
Report No. RO 1702-881

Cleanroom[®] Suitable Materials

Corian DuPont
Hydrogen Peroxide Absorption /
Desorption: fast

FLOORING & COATING

Hydrogen Peroxide Absorption/Desorption

Qualification Certificate

We hereby certify that the material stated above, provided by

Roche Diagnostics GmbH
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1702-881.

The hydrogen peroxide absorption/desorption of Corian DuPont (color: white) was investigated at the stated test parameters. Using the procedure laid down in VDI 2083 Part 20, the following test results were obtained:

Ø k-value [min]	Standard deviation [min]	Classification
7.21	1.17	fast

- < 5 min:..... non-absorptive
- 5-15 min:..... fast
- 15-60 min:..... average
- > 60 min:..... slow
- Not determinable:..... catalytic activity

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, May 5, 2017
Place, date of first document issued

--
Place, current date

on behalf of 
Udo Gommel, Project manager Fraunhofer IPA

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.
Further information:
www.tested-device.com.
Please visit www.ipa-csm.com.