



# Cleanroom<sup>®</sup> Suitable Materials

Roche Diagnostics GmbH  
Report No. RO 1702-882

Powder coated wall panel  
Biol. Resistance: very good

## FLOORING & COATING

### Biological Resistance

### Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

**Roche Diagnostics GmbH**  
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1702-882.

The powder coated wall panel (color: white) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification according to VDI 2083 Part 18 and ISO 846:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	1	very good
Bacteria (Procedure C)	1	very good
<b>Overall result</b>	<b>1</b>	<b>very good</b>

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:

[www.tested-device.com](http://www.tested-device.com).

Please visit [www.ipa-csm.com](http://www.ipa-csm.com).

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, May 5, 2017

Place, date of first document issued

--

Place, current date

on behalf of

Udo Gommel, Project manager Fraunhofer IPA