



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

OCTANORM-Vertriebs-GmbH  
OCV-SM60

**Report No. OC 1706-924**

### Hygienic Design

### Qualification Certificate

This is to certify that the product mentioned above, provided by

**OCTANORM-Vertriebs-GmbH**  
Filderstadt, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number OC 1706-924.

The metal facing wall system 60 mm OCV-SM60 is principally suitable for use in hygienic areas up to the following GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class B

However, this recommendation only pertains to the operating utility when in a resting state. An overall assessment of the OCV-SM60 can only be made after its installation in the production line.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

OC 1706-924  
Report No. first document

Stuttgart, 2. August 2017  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Frank Bürger, Project Manager Fraunhofer IPA

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.  
Further information:  
[www.tested-device.com](http://www.tested-device.com)

DUPLICATE