



Sika Deutschland GmbH
Report No. SI 1709-952

Cleanroom[®] Suitable Materials

Sikafloor-264 N
Particle (vs. PA6): ISO 3

FLOORING & COATING

DUPLICATE

Particle Emission
Partikelemission

Statement of Qualification

Qualifizierungsbescheinigung

Customer

Auftraggeber

Sika Deutschland GmbH
Kornwestheimer Strasse 103-107
70439 Stuttgart
Germany

Material tested

Untersuchter Werkstoff

Sikafloor-264 N (gray|Grau)
For the specific product data such as manufacturing date and serial number please refer to the test report.
Produktspezifische Daten wie Herstellungsdatum und Seriennummer sind dem Prüfbericht zu entnehmen.

Measurement of particle emission (airborne) from material when subjected to friction

Emissionsmessung luftgetragener Partikel bei tribologischer Belastung

Standards/Guidelines:

Standards/Richtlinien:

ISO 14644-1; VDI 2083 Part 17
The norms stated refer to the relevant editions applicable at the time of the tests.
Die angegebenen Normen beziehen sich jeweils auf die zum Zeitpunkt der Untersuchungen gültige Fassung.

Test environment parameters:

Testparameter der Prüfumgebung:

- Cleanroom Air Cleanliness Class|Reinraum Luftreinheitsklasse..... ISO 1 (according to|gemäß ISO 14644-1):.....
- Airflow velocity|Luftströmungsgeschwindigkeit:.....0.45 m/s
- Airflow type|Strömungsführung:vertical laminar flowvertikale laminare Strömung
- Temperature|Temperatur:.....71.6°F±0.9°F|22°C±0,5°C
- Relative humidity|Relative Feuchte:45%±5%

Test procedure parameters:

Testparameter der Versuchsdurchführung:

Reel-on-disc test vs. PA6; normal force 300N
Rolle-Scheibe-Test vs. PA6; Normalkraft 300N

Test result / Classification

Untersuchungsergebnis/Klassifizierung

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1: Die bei tribologischer Belastung der unten aufgeführten Werkstoffpaarung emittierten partikulären Kontaminationen liegen bei den angegebenen Testparametern innerhalb der Grenzwerte der jeweils zugeordneten Luftreinheitsklasse gemäß ISO 14644-1:

Material pairing and test Werkstoffpaarung		Suitable for Air Cleanliness Class Geeignet für Luftreinheitsklasse (ISO 14644-1)	
Sikafloor-264 N (gray Grau)	vs. PA6	ISO Class: 3	ISO-Klasse: 3
Reel-on-disc test Rolle-Scheibe-Test Normal force Normalkraft 300N			

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

For further information about the test environment and parameters, please refer to the Fraunhofer IPA test report.

Die für die Qualifizierung verwendeten Messeinrichtungen werden regelmäßig kalibriert und sind auf nationale und internationale Normale rückführbar. Sofern keine nationalen Normale existieren, entspricht das Messverfahren den derzeit gültigen technischen Regeln und Normen. Die Dokumentation kann bei Bedarf eingesehen werden.

Weitere Informationen bezüglich Prüfumgebung und -parameter entnehmen Sie bitte dem Prüfbericht des Fraunhofer IPA.

Fraunhofer Institute for
Manufacturing Engineering and Automation IPA

Department of Ultraclean Technology
and Micromanufacturing

Nobelstrasse 12
70569 Stuttgart
Germany

SI 1709-952
Report No. first document

--
Report No. current document

on behalf of

Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA

Stuttgart, November 9, 2017
Place, date of first document issued

--
Place, current date

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.