



Fraunhofer

TESTED[®] DEVICE

REIKU GmbH
cor tubing system NW23
Report No. RE 1805-1038

Particle Emission

Qualification Certificate

This is to certify that the product mentioned above, provided by

REIKU GmbH Kabelschutzsysteme
Wiehl-Bomig, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number RE 1805-1038.

The sample construction clean room corrugated tubing system NW23 incl. fasteners and connectors (color: black) was assessed in compliance with ISO 14644-14. When operated under the specified test conditions, it is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Classes according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
$v_1 = 0.5 \text{ m/s}; a_1 = 1.0 \text{ m/s}^2$	4
$v_2 = 1.0 \text{ m/s}; a_2 = 2.0 \text{ m/s}^2$	5
$v_3 = 2.0 \text{ m/s}; a_3 = 4.0 \text{ m/s}^2$	5
Overall result	5

DUPLICATE

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

RE 1805-1038 Stuttgart, June 18, 2018
Report No. first document Place, date of first document issued

-- --
Report No. current document Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA