



FAKOLITH Farben GmbH
Report No. FA 1803-1018

Cleanroom[®] Suitable Materials

DISPERLITH FOODGRADE

H₂O₂ Absorption/Desorption:
medium

FLOORING & COATING

Hydrogen Peroxide Absorption/Desorption

Qualification Certificate

We hereby certify that the material stated above, provided by

FAKOLITH Farben GmbH
Fürth, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number FA 1803-1018.

The hydrogen peroxide absorption/desorption of DISPERLITH FOODGRADE was investigated at the stated test parameters, providing the following test result according to VDI 2083 Part 20:

Ø k-value [min]	Standard deviation [min]	Classification
29.5	2.3	medium

- ≤ 5 min: non-absorptive
- > 5 - ≤ 15 min: fast
- > 15 - ≤ 60 min: medium
- > 60 min: slow
- Not determinable: catalytic activity

DUPLICATE

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

FA 1803-1018
Report No. first document
--
Report No. current document

Stuttgart, April 13, 2018
Place, date of first document issued
--
Place, current date

on behalf of
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA