



**Fraunhofer**

**TESTED<sup>®</sup>  
DEVICE**

Advantest Europe GmbH  
E2760 FAE 18kW 100920  
**Report No. AD 1811-1079**

DUPLICATE

Statement of  
Qualification

Particle Emission

# Statement of Qualification

**Customer** Advantest Europe GmbH  
Herrenberger Strasse 130  
71034 Böblingen  
Germany

**Component tested**

Category: Process Equipment

Subcategory: Heating and Cooling

Product name: Cooling system E2760 FAE 18kW 100920  
(manufacturing date: 2018; serial number: 100920; weight: 74 kg; heat transfer medium: water; type of pump: Grundfos MGE90C 2-CMS2A-HA)

## Random sampling of particle emissions (airborne) at representative sites

Standards/Guidelines: ISO 14644-1, -14  
The norms stated generally refer to the version valid at the time of the tests.

Test devices: Optical particle counter:  
LasAir II 110 and LasAir III 110 with measuring ranges  $\geq 0.1 \mu\text{m}$ ,  $\geq 0.2 \mu\text{m}$ ,  $\geq 0.3 \mu\text{m}$ ,  $\geq 0.5 \mu\text{m}$ ,  $\geq 1.0 \mu\text{m}$  and  $\geq 5.0 \mu\text{m}$

Test environment parameters:

- Cleanroom Air Cleanliness Class (according to ISO 14644-1):..... ISO 1
- Airflow velocity:.....0.45 m/s
- Airflow pattern:..... vertical laminar flow
- Temperature: .....22 °C  $\pm$  0.5 °C
- Relative humidity: ..... 45 %  $\pm$  5 %

Test procedure parameters:

- Current: .....  $I_N = 6.7 \text{ A}$
- Voltage:.....  $U_N = 200\text{-}240 \text{ V}$
- Heat transfer medium:.....water
- Water flow: .....  $Q = 1 \text{ l/min}$

## Test result / Classification

When operated under the specified test conditions, the Cooling system E2760 FAE 18kW 100920 is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Water flow $Q = 1 \text{ l/min}$	7
<b>Overall result</b>	<b>7</b>

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA

Department of Ultraclean Technology and Micromanufacturing

Nobelstrasse 12  
70569 Stuttgart  
Germany

AD 1811-1079  
Report No. first document

Stuttgart, January 9, 2019  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA