



Fraunhofer

TESTED[®] DEVICE

DYNACO
D-313 CLEANROOM LF
Report No. DY 1203-590

Qualification Certificate

This is to certify that the product mentioned above, provided by

DYNACO Europe N.V.
9310 Moorsel (Aalst), Belgium

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number DY 1203-590.

Both the clean side of the D-313 CLEANROOM LF as well as the side of the driving mechanism are suitable for use in cleanrooms fulfilling Air Cleanliness Class 6 according to ISO 14644-1.

Both sides of the D-313 CLEANROOM LF are principally recommended for use in hygienic areas up to GMP Class C. However, this only applies for the assessed operating utility in a resting state and the recommendation needs to be reconsidered once the devices have been installed into a production line.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, April 27, 2012

i.A. 
Project manager

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:
www.tested-device.com