



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Tarkett AB  
iQ Granit

Report No. TA 1501-744

### Qualification Certificate

This is to certify that the product mentioned above, provided by


**Tarkett AB**  
Ronneby, Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number TA 1501-744.

Chemical resistance	1 h	3 h	6 h	24 h
Formalin 37 %	0	0	0	0
Ammoniac 25 %	0	0	0	0
Hydrogen peroxide 30 %	0	0	0	0
Sulfuric acid 5 %	0	0	0	0
Phosphoric acid 30 %	0	0	0	0
Peracetic acid 15 %	0	1	1	2
Hydrochloric acid 5 %	0	0	0	0
Isopropanol 100 %	0	0	0	3
Sodium hydroxide 5 %	0	0	0	0
Sodium hypochlorite 5 %	0	0	0	0
<b>Classification</b>	<b>1 / very good</b>			

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, April 9, 2015

i.A.   
Frank Bürger, Project manager Fraunhofer IPA

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:  
[www.tested-device.com](http://www.tested-device.com)