



Tarkett AB  
Report No. TA 1403-699

# Cleanroom<sup>®</sup> Suitable Materials

iQ Natural  
Particle (vs. PA6): ISO 3

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Tarkett AB**  
Ronneby, Sweden

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TA 1403-699.

iQ Natural (color 172) was tested regarding particle emission during the application of frictional stress according to VDI 2083-17. The tested material obtained the following classification:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
iQ Natural (color 172)	vs. PA6	ISO Class: 3
Reel-on-disc test Normal force 300N		

Detailed information regarding specific product data such as date of manufacture and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, September 1, 2014

i. A.   
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on [www.tested-device.com](http://www.tested-device.com).

For more CSM information, please visit [www.ipa-csm.com](http://www.ipa-csm.com).