



Fraunhofer

TESTED[®] DEVICE

Gerflor GmbH Floor Covering
MIPOLAM BIOCONTROL
Report No. GE 0802-427

DUPLICATE

Qualification Certificate

This is to certify that the products mentioned below manufactured by the company

Gerflor Mipolam GmbH

Mülheimerstrasse 27
D-53840 Troisdorf

has been awarded a Fraunhofer IPA Qualification seal bearing the report number GE 0802-427.

The floor covering MIPOLAM BIOCONTROL has performed following tests:

- Particle emission (airborne) while frictional loaded
- Outgassing behavior relative to anions, ammonium nitrogen compounds and volatile organic compounds (VOC)
- Electrostatic discharge measurements at representative points
- Resistance to ground, system resistance and walkingtest
- Surface cleanliness behavior amongst representative cleaning methods
- Surfaces concerning adhesion of micro organisms.
- Presence of metabolizable carbon-based products.

Detailed information and parameters of the test environment can be found in the test report compiled by the Fraunhofer-Gesellschaft.

Certified on August 18th 2008.

The duration of the validity of this certificate is unlimited. For further information visit our website at www.ipa-qualification.com.

Stuttgart, Germany, August 18th 2008

i. A. 
Signature



Fraunhofer Institut
Produktionstechnik und
Automatisierung