

## Fraunhofer

## TESTED® DEVICE

Brecon Group
Formica High Pressure Laminate
Report No. BR 1804-1024

Statement of Qualification

Hydrogen Peroxide Absorption/Desorption





## **Statement of Qualification**

**Customer** Brecon Cleanroom Systems B.V.

Droogdokkeneiland 7 5026 SP Tilburg The Netherlands

**Component tested** 

Category: Materials

Subcategory: Material Composites

Product name: Formica High Pressure Laminate

(manufacturing date: 4/2018; article number: BM-W-HRW-101;

batch number: 1285727)

Hydrogen peroxide absorption / desorption

Methodics:

Air-conditioned laboratory environment:

Test procedure parameters:

VDI 2083 Part 20

The norms stated generally refer to the version valid at the time of the tests

emperature: ......22 °C ± 0.5 °C

Emission test cell volume:	16.5 cm <sup>3</sup>
Exposed surface area:	33 cm²
• H <sub>2</sub> O <sub>2</sub> vapor concentration:	40 ± 20 ppm (V)
• Exposure duration:	
Air exchange rate during aeration:	

.23°C ± 2°C

Test result/Classification

The hydrogen peroxide absorption/desorption of Formica High Pressure Laminate was investigated with the stated test parameters. Using the procedure laid down in VDI 2083 Part 20, the following test result was obtained:

<b>Ø k-value</b> [min]	Standard deviation [min]	Classification
11.5	0.9	fast

The k-value represents the required decay time to reduce the hydrogen peroxide vapor concentration measured at the beginning of the aeration phase to one tenth of the original concentration. The material classification is based on three separate measurements. The blank value of the test setup is subtracted from each measurement value. The medium k-value is transferred to the following classification:

• ≤ 5 min:	non-absorptive
• > 5-≤ 15 min:	fast
• > 15-≤ 60 min:	medium
• > 60 min:	slow
Not determinable:	catalytic activity

The k-value can only be used to make a comparative material assessment. Provided the maximum hydrogen peroxide vapor concentration during material exposure is within the defined limit, it does not affect the calculated k-values.

The measuring devices used for the qualification tests are calibrated at regular intervals; their results can be traced back to national and international standards. In cases where no national standards exist, the test procedure implemented complies with the technical regulations and norms applicable at the time of the test. The relevant documentation can be viewed on request at any time.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Fraunhofer Institute for Manufacturing Engineering and Automation IPA

Department of Ultraclean Technology and Micromanufacturing

Nobelstrasse 12 70569 Stuttgart Germany BR 1804-1024

Report No. first document

Stuttgart, August 1, 2018

Place, date of first document issued

Report No. current document

ace, current date

on behalf of River

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

