



ContiTech
Report No. CO 1711-972

Cleanroom[®] Suitable Materials

Conti Multi-Protect
Chemical Resistance: excellent

FLOORING & COATING

Chemical Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

ContiTech Elastomer-Beschichtungen GmbH
Northeim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number CO 1711-972.

The chemical resistance tests on the Conti Multi-Protect (anthracite) are performed in accordance with ISO 2812-1. Therefore the damages according to ISO 4628-1 and VDI 2083 Part 17 have been transferred to the following classification:

Chemicals	Chemical resistance	Chemicals	Chemical resistance
Formalin 37 %	excellent	Phosphoric acid 30 %	excellent
Ammoniac 25 %	excellent	Hydrochlorid acid 5 %	excellent
Isopropanol 100 %	excellent	Hydrogen peroxide 30 %	excellent
Sulfuric acid 5 %	excellent	Sodium hydroxide 5 %	excellent
Peracetic acid 15 %	excellent	Sodium hypochlorite 5 %	excellent
Overall result	excellent		

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

CO 1711-972
Report No. first document

--
Report No. current document

Stuttgart, February 27, 2018
Place, date of first document issued

--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project manager Fraunhofer IPA