



Fraunhofer

TESTED[®] DEVICE

OMS s.r.o.

RELAX XTP PAR 4x54W

Report No. OM 1206-601

Qualification Certificate

This is to certify that the product mentioned above, provided by

OMS s.r.o.

Dojč, Slovak Republic

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number OM 1206-601.

The lighting system RELAX XTP-IP65 PV PAR T5 4x54W,350G, EB A2,9003 is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 3 according to ISO 14644-1.

It must be pointed out, that according to ISO 14644-1 cleanrooms classes 1 to 5 have a high number of filters, which makes the use of lighting systems partly impossible. Cleanrooms with horizontal laminar flow are an exception.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, July 27, 2012

i. A. 
Project manager

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:
www.tested-device.com

DUPLICATE



Fraunhofer

IPA