



ContiTech
Report No. CO 1711-972

Cleanroom[®] Suitable Materials

Conti Multi-Protect
Biological Resistance: very good

FLOORING & COATING

Biological Resistance

Qualification Certificate

We hereby certify that the material stated above, provided by

ContiTech Elastomer-Beschichtungen GmbH
Northeim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number CO 1711-972.

The Conti Multi-Protect (anthracite) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification according to VDI 2083 Part 18 and ISO 846:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	1	very good
Bacteria (Procedure C)	0	excellent
Overall result	1	very good

DUPLICATE

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

CO 1711-972
Report No. first document
--
Report No. current document

Stuttgart, February 27, 2018
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project manager Fraunhofer IPA