



Sika AG
Report No. SI 1403-695

Cleanroom[®] Suitable Materials

Sikafloor-156 Screed
Biol. Resistance: excellent

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika AG
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1403-695.

Sikafloor-156 Screed (natural) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification.

Classification	ISO (acc. to ISO 846)	CSM
Fungi (Procedure A)	0	excellent
Bacteria (Procedure C)	0	excellent
Overall Result	0	excellent

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, June 26, 2014

i. A.
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.

DUPLICATE