



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

Wiedemann GmbH  
BE H-HYG-100 two-part S  
**Report No. WI 1708-939**

### Hygienic Design

### Qualification Certificate

This is to certify that the product mentioned above, provided by

**Wiedemann GmbH**  
Husum, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE  
bearing the report number WI 1708-939.

The Floor Drain System BE HYG-100 two-part adjustable height  
vertical is principally suitable for use in hygienic areas up to the  
following GMP Class according to EU GMP Annex 1:

Suitability
up to GMP Class C

This only applies for the test piece Floor Drain System BE HYG-  
100 two-part adjustable height vertical, an overall assessment  
would need to be made after its installation in a manufacturing  
environment.

Detailed information and parameters of the test environment can  
be found in the Fraunhofer IPA test report.

WI 1708-939  
Report No. first document

Stuttgart, October 23, 2017  
Place, date of first document issued

--  
Report No. current document

--  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA

This document only  
applies to the named  
product in its original state  
and is valid for a period of  
5 years from the date the  
first document was issued.  
The document can be  
verified under  
[www.tested-device.com](http://www.tested-device.com).

DUPLICATE