



Fraunhofer

TESTED[®] DEVICE

Brecon Group
Brecon Cassette Panel System
Report No. BR 1804-1024

Particle Emission

Qualification Certificate

This is to certify that the product mentioned above, provided by

Brecon Cleanroom Systems B.V.
Tilburg, The Netherlands

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number BR 1804-1024.

The Brecon Cassette Panel System (color: RAL 9010) was assessed in compliance with ISO 14644-14. When operated under the specified test conditions, it is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
structure-borne noise: approx. 5 to 50Hz	3
Overall result	3

DUPLICATE

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

BR 1804-1024
Report No. first document

Stuttgart, August 1, 2018
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA