



TREMCO CPG MALAYSIA  
Report No. TR 2210-1354

# Cleanroom<sup>®</sup> Suitable Materials

Flowshield CR  
Particle (vs. PA6 Nylon): ISO 3

## FLOORING & COATING

Single product  
Particle Emission

DUPLICATE

## Qualification Certificate

We hereby certify that the material stated above, provided by

TREMCO CPG MALAYSIA SDN BHD  
Kuala Lumpur, Malaysia

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number TR 2210-1354.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Flowshield CR (light gray)	vs. PA6	ISO Class: 3
Reel-on-disc test; normal force: 300N		

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

TR 2210-1354  
Report No. first document  
--  
Report No. current document

Stuttgart, March 3, 2023  
Place, date of first document issued  
--  
Place, current date  
on behalf of 