



# Cleanroom<sup>®</sup> Suitable Materials

Nanten Oy  
Report No. NA 1407-717

Nanten SL Epoxy Coating  
Biol. Resistance: good

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Nanten Oy**  
Tuusula, Finland

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NA 1407-717.

Nanten SL Epoxy Coating (light grey 257) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification:

	Test	Classification
<b>Biological resistance</b> (acc. to ISO 846)	Fungi (Procedure A)	ISO/CSM: 2/good
	Bacteria (Procedure C)	ISO/CSM: 1/very good
<b>Overall result</b>		<b>ISO/CSM: 2/good</b>

DUPLICATE

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, September 12, 2014

i. A.   
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on [www.tested-device.com](http://www.tested-device.com).

For more CSM information, please visit [www.ipa-csm.com](http://www.ipa-csm.com).