



Fraunhofer

TESTED[®] DEVICE

N.Y.R. Biological Safety
Cleanroom Laboratory
Report No. NY 0512-339

DUPLIKAT

IPA Qualification Certificate

This is to certify that the cleanroom laboratory manufactured by the company

N.Y.R. Limited Partnership

159 Charansanitwong Rd.
Bangkok 10700
Thailand

has been awarded an IPA Qualification Seal bearing the report number NY 0512-339.

The Biological Safety Cleanroom Laboratory at the Chulalongkorn University, Bangkok, installed by N.Y.R. Limited Partnership, is suitable for operations that are depending on a P3 laboratory according to guideline M 057 BG Chemie. The above mentioned cleanroom laboratory is fulfilling the specifications of Air Cleanliness Class 7 according to ISO 14644-1 (class 10000 according US Federal Standard 209E).

For details see report at Fraunhofer IPA or above mentioned certified company.

Certified on 07th December 2005.

The duration of the validity of this certificate is unlimited. For further information visit our website at <http://www.ipa-qualification.com>

Stuttgart, Germany, 07th December 2005

Signature



Fraunhofer
Institut
Produktionstechnik und
Automatisierung