



**StoCretec GmbH**  
**Report No. ST 1803-1014**

# Cleanroom<sup>®</sup> Suitable Materials

**StoPox WHG Deck 110**  
**Outgassing VOC/SVOC**  
**ISO-ACC<sub>m</sub> Class -7.9 / <-9.6**

## FLOORING & COATING

### Outgassing Behavior VOC/SVOC

### Qualification Certificate

We hereby certify that the material stated above, provided by

**StoCretec GmbH**  
 Kriftel, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number ST 1803-1014.

The outgassing behavior of StoPox WHG Deck 110 (color: pebble gray) at the stated temperatures was investigated according to VDI 2083 Part 17. Based on the outgassing rates determined for the specific surfaces, the following material classification was made for the corresponding Contaminant Category:

Contaminant Category (x)	SER <sub>a</sub> <sup>1)</sup> 23 °C [g/m <sup>2</sup> s]	SER <sub>a</sub> <sup>1)</sup> 90 °C [g/m <sup>2</sup> s]	ISO-ACC <sub>m</sub> Class (x) based on 23 °C
VOC	1.4 x 10 <sup>-8</sup>	1.6 x 10 <sup>-5</sup>	<b>-7.9</b>
SVOC	< 2.8 x 10 <sup>-10</sup>	< 4.6 x 10 <sup>-9</sup>	<b>&lt; -9.6</b>
Amines	< 2.8 x 10 <sup>-10</sup>	1.5 x 10 <sup>-8</sup>	--
Organophosphates	< 2.8 x 10 <sup>-10</sup>	< 4.6 x 10 <sup>-9</sup>	--
Siloxanes	< 2.8 x 10 <sup>-10</sup>	< 4.6 x 10 <sup>-9</sup>	--
Phthalates	< 2.8 x 10 <sup>-10</sup>	< 4.6 x 10 <sup>-9</sup>	--

<sup>1)</sup> SER<sub>a</sub>: Area-specific emission rate

DUPLICATE

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

ST 1803-1014  
 Report No. first document  
 --  
 Report No. current document

Stuttgart, July 30, 2018  
 Place, date of first document issued  
 --  
 Place, current date

on behalf of   
 Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA