



Sika AG
Report No. SI 1412-740

Cleanroom[®] Suitable Materials

Sikafloor-210 PurCem
Biol. Resistance: good

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika AG
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1412-740.

Sikafloor-210 PurCem (RAL 7032) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification:

	Test	Classification
Biological resistance (acc. to ISO 846)	Fungi (Procedure A)	ISO/CSM: 2/good
	Bacteria (Procedure C)	ISO/CSM: 2/good
Overall result		ISO / CSM: 2/good

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, March 23, 2015

i. A.
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.

DUPLICATE