



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

AMF Ceiling System  
Kombimetall  
Report No. AM 0112-253

DUPLIKAT

### IPA Qualification Certificate

This is to certify that the product mentioned below manufactured by the company

**AMF Mineralplatten GmbH Betriebs KG**

Elsenthal 15  
D-94481 Grafenau

has been awarded an IPA Qualification Seal bearing the report number AM 0112-253.

The ceiling plate "Kombimetall" of the company AMF Mineralplatten GmbH Betriebs KG, is suitable for use in cleanrooms fulfilling the specifications of "Class 1.000" (in accordance with US Federal Standard 209E).

The ceiling plate "Kombimetall" is tested on its volatile organic emission at given test temperatures.

Detailed information and parameters of the test environment can be found in the IPA Test Report compiled by the Fraunhofer Society.

Certified on January 31<sup>st</sup>, 2002.

The duration of the validity of this certificate is unlimited. For further information visit our website at <http://www.ipa-qualification.com>

Stuttgart, Germany, January 31<sup>st</sup>, 2002

Signature



**Fraunhofer** Institut  
Produktionstechnik und  
Automatisierung