



Fraunhofer

TESTED[®] DEVICE

Cleanroom Laboratory
Report No. NY 0211-282

DUPLIKAT

IPA Qualification Certificate

This is to certify that the product mentioned below manufactured by the company

N.Y.R. Limited Partnership

159 Charansanitwong Rd.
Bangkok 10700, Thailand

has been awarded an IPA Qualification Seal bearing the report number NY 0211-282.

The biosafety cleanroom laboratory installed by N.Y.R. Limited Partnership at the Silpakorn University, Nakornpathom, is suitable for operations that are depending on a P3 laboratory according to guideline M 057 BG Chemie. The above mentioned cleanroom laboratory is fulfilling the specifications of Class C according to EU GMP-Guideline vol. 4, annex 1.

Detailed information and parameters of the test environment can be found in the IPA Test Report compiled by the Fraunhofer Society.

Originally certified November 7th, 2002.

The duration of the validity of this certificate is unlimited. For further information visit our website at <http://www.ipa-qualification.com>

Stuttgart, Germany, November 7th, 2002

A handwritten signature in black ink, appearing to read 'Andreas Schütz'.

Signature



Fraunhofer

Institut
Produktionstechnik und
Automatisierung