



Sika AG
Report No. SI 0904-480

Cleanroom[®] Suitable Materials

Sikafloor-263 SL
Particle (vs. PA6): GMP A

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated below which was provided by

Sika Deutschland GmbH

Kornwestheimerstraße 103-107
D-70439 Stuttgart

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 0904-480.

The tests performed in accordance with CSM procedures included particle emission during the application of frictional stress. The tested material obtained following classification in accordance with the standard(s) listed below.

Material (Mat.)	Sikafloor-263 SL	
Particle	Reel-on-disc test; Normal force 300 N Mat. vs. PA6	GMP Class A (see EC-GMP Annex 1, in operation)

Detailed information regarding the test environment and parameters used can be obtained from the CSM Test report number SI 0904-480 issued by the Fraunhofer-Gesellschaft.

The validity of this certificate is indefinite. For more information, visit our website at www.ipa-csm.com.

Stuttgart, Germany, August 24, 2009

i. A. 
Signature project manager



Fraunhofer Institut
Produktionstechnik und
Automatisierung