



Sika AG
Report No. SI 0706-406

Cleanroom[®] Suitable Materials

Sikafloor-235 ESD
Particle (vs. PA6): GMP A

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated below which was provided by

Sika Deutschland GmbH

Kornwestheimerstraße 103-107
D-70439 Stuttgart

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 0706-406.


The tests performed in accordance with CSM procedures included particle emission during the application of frictional stress.

Material (Mat.)	Sikafloor-235 ESD	
Particle	Reel-on-disc test; Normal force 225 N Mat. vs. PA6	GMP Class A (see EG-GMP Annex 1)

Detailed information regarding the test environment and parameters used can be obtained from the CSM Test report number SI 0706-406 issued by the Fraunhofer-Gesellschaft.

The validity of this certificate is indefinite. For more information, visit our website at www.ipa-csm.com.

Stuttgart, Germany, July 15th 2009

i. A. 
Signature project manager



Fraunhofer Institut
Produktionstechnik und
Automatisierung