



Fraunhofer

TESTED[®] DEVICE

Saint-Gobain Ecophon
Hygiene Advance A C3
Report No. EC 0912-502

DUPLICATE

Qualification Certificate

This is to certify that the product mentioned below provided by the company

Saint-Gobain Ecophon AB

Box 500
260 31 Hyllinge
Sweden

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number EC 0912-502.

The ceiling system Hygiene Advance A C3 is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 3 according to ISO 14644-1.

At the ceiling system Hygiene Advance A C3 a cleaning success of 100 % of all detectable particles between 2 µm and 200 µm was achieved using the clean agent Elma Clean 100.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The validity of this certificate applies only to the above mentioned product in this particular condition. For further information visit our website at www.ipa-qualification.com.

Stuttgart, March 4, 2010

i.A. 
Project manager