



Sika AG
Report No. SI 1103-544

Cleanroom[®] Suitable Materials

Sikagard-Wallcoat N
Biol. Resistance: excellent

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated above which, provided by

Sika Deutschland GmbH

Kornwestheimerstraße 103-107
70439 Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1103-544.

The tests are performed in accordance with CSM procedures included particle emission during the application of frictional stress and biological resistance. The tested material obtained following classification in accordance with the standards listed below.

Material	Sikagard-Wallcoat N pink	
	Test	Classification
Biological Resistance (acc. to ISO 846)	Fungi (Procedure A)	ISO/CSM: 0/excellent
	Bacteria (Procedure C)	ISO/CSM: 0/excellent
Overall Result Biological Resistance		ISO / CSM: 0 / excellent

Detailed test information regarding the sample (serial number, color, batch number, etc.), environment and parameters used, can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, May 31, 2011

i. A.
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified under www.tested-device.com

For more CSM information please visit: www.ipa-csm.com