



Sika AG
Report No. SI 1008-533

Cleanroom[®] Suitable Materials

Sika-ComfortFloor
Particle (vs. PA6): ISO 2

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated below which was provided by

Sika Deutschland GmbH

Kornwestheimerstraße 103-107
70439 Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1008-533.

The tests performed in accordance with CSM procedures included particle emission during the application of frictional stress and outgassing at various temperatures. The tested material obtained following classification in accordance with the standard(s) listed below.

Material (Mat.)	Sika-ComfortFloor Wearing course: Sikafloor-330 Seal coat: Sikafloor-305 W RAL 7035	
Particle	Reel-on-disc test; Normal force 300 N; Mat. vs. PA6	ISO Class 2 (see ISO 14644-1)

Detailed test information regarding the sample (serial number, color, batch number, etc.), environment and parameters used, can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, May 11, 2011

i. A.
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified under www.tested-device.com

For more CSM information please visit: www.ipa-csm.com