



Cleanroom[®] Suitable Materials

Sika AG
Report No. SI 1103-544

Sikagard-Wallcoat N
TVOC (23°C/90°C): ISO -9.6 / tested

Flooring & Coating

DUPLICATE

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika Deutschland GmbH

Kornwestheimerstraße 103-107
70439 Stuttgart, Germany


has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1103-544.

The tests are performed in accordance with CSM procedures included outgassing at various temperatures. The tested material obtained following classification in accordance with the standard listed below.

	Test	Classification
Outgassing at 23 °C / 73 °F	TVOC	ISO-AMC Class -9.6 (see ISO 14644-8)
Outgassing at 90 °C / 194 °F	Amines Organo-phosphates Siloxanes Phthalates	not detectable not detectable not detectable not detectable

The tested material was Sikagard-Wallcoat N pink. Detailed test information regarding the sample (serial number, color, batch number, etc.), environment and parameters used, can be obtained from the CSM test report SI 1103-544 issued by the Fraunhofer-Gesellschaft.

Stuttgart, May 31, 2011

i. A. 
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified under www.tested-device.com

For more CSM information please visit: www.ipa-csm.com