



Fraunhofer

TESTED[®] DEVICE

Knauf AMF GmbH & Co. KG
THERMATEX Alpha
Report No. KN 1202-589

Qualification Certificate

This is to certify that the product mentioned above, provided by

Knauf AMF GmbH & Co. KG
Grafenau, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number KN 1202-589.

The ceiling system THERMATEX Alpha is suitable for use in cleanrooms fulfilling the Air Cleanliness Class 4 according to ISO 14644-1.

It must be pointed out, that according to ISO 14644-1 cleanrooms classes 1 to 5 have a high number of filters, which makes the use of ceiling elements partly impossible. Cleanrooms with horizontal laminar flow are an exception.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, April 13, 2012

i.A. 
Project manager

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:
www.tested-device.com