



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

OWA GmbH  
OWAtecta Systems S 33/S 45  
**Report No. OW 1003-518**

DUPLICATE

### Qualification Certificate

This is to certify that the products mentioned below provided by the company

#### Odenwald Faserplattenwerk GmbH

Dr.-F.-A.-Freundt-Straße 3  
63916 Amorbach  
Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number OW 1003-518.

The ceiling systems OWAtecta S 33/S 45 in combination with fitted light OWA-Opal/OWA-Opal E and the filter OWAclean-air diffuser outlet are suitable for use in cleanrooms fulfilling the Air Cleanliness Class 2 according to ISO 14644-1.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The validity of this certificate applies only to the above mentioned product in this particular condition. For further information visit our website at [www.ipa-qualification.com](http://www.ipa-qualification.com).

Stuttgart, August 3, 2010

i. A.   
Project manager