



Fraunhofer

TESTED[®] DEVICE

ROCKFON

VertiQ surface, White

Report No. RO 1408-718

Qualification Certificate

This is to certify that the product mentioned above, provided by

ROCKWOOL International A/S, ROCKFON
Hedehusene, Denmark

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number RO 1408-718.

The chemical resistance tests on the VertiQ surface, White are performed in accordance with ISO 2812-1. Therefore the damages according to ISO 4628-1 and VDI 2083-17 have been transferred to the following classification:

Chemical resistance	1 h	3 h	6 h	24 h
Chlorine 1000 ppm	0	0	0	1
Ethanol 70 %	0	0	0	0
Classification	1 / very good			

Due to the fact that the tested material is permeable, the test result only applies to the tested material.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, September 9, 2014

i. A. 
Udo Gommel, Fraunhofer IPA

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:
www.tested-device.com