



Cleanroom[®] Suitable Materials

GERFLOR
Report No. GE 1505-761

GTI EL5
Outgassing VOC (23°C/90°C):
ISO-ACC_m Class -8.0 / tested

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

GERFLOR
SAINT PAUL TROIS CHATEAUX, France


has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 1505-761.

GTI EL5 (light grey) was tested regarding outgassing at various temperatures according to VDI 2083-17. The tested material obtained the following classification:

| Test temperatures | Family of contaminants | Specific emission rate [g/m ² s] | ISO-ACC _m Class (x) |
|-------------------|------------------------|---|--------------------------------|
| 23 °C / 73 °F | VOC | 1.1 x 10 ⁻⁰⁸ | -8.0 |
| 90 °C / 194 °F | Amines | not detectable | -- |
| | Organophosphates | not detectable | -- |
| | Siloxanes | not detectable | -- |
| | Phthalates | not detectable | -- |

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, August, 13, 2015

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.