



GERFLOR
Report No. GE 1505-761

Cleanroom[®] Suitable Materials

MIPOLAM BIOCONTROL EL5
Outgassing VOC (23°C/90°C):
ISO-ACC_m Class -7.7 / tested

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

GERFLOR
 SAINT PAUL TROIS CHATEAUX, France


has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number GE 1505-761.

MIPOLAM BIOCONTROL EL5 (light grey) was tested regarding outgassing at various temperatures according to VDI 2083-17. The tested material obtained the following classification:

Test temperatures	Family of contaminants	Specific emission rate [g/m ² s]	ISO-ACC _m Class (x)
23 °C / 73 °F	VOC	2.1 x 10 ⁻⁰⁸	-7.7
90 °C / 194 °F	Amines	not detectable	--
	Organophosphates	not detectable	--
	Siloxanes	not detectable	--
	Phthalates	not detectable	--

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, August 13, 2015

i. A. 
 Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.