



# Cleanroom<sup>®</sup> Suitable Materials

Mapei S.p.A.  
Report No. MA 1502-748

MAPEFLOOR I302 SL  
Biol. Resistance: very weak

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Mapei S.p.A.**  
Milano, Italy

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number MA 1502-748.


MAPEFLOOR I302 SL (white) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification:

	Test	Classification
<b>Biological resistance</b> (acc. to ISO 846)	Fungi (Procedure A)	ISO/CSM: 2/good
	Bacteria (Procedure C)	ISO/CSM: 4/very weak
<b>Overall result</b>		<b>ISO/CSM: 4/very weak</b>

DUPLICATE

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, December 21, 2015

i. A.   
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on [www.tested-device.com](http://www.tested-device.com).

For more CSM information, please visit [www.ipa-csm.com](http://www.ipa-csm.com).