



Cleanroom[®] Suitable Materials

Mapei S.p.A.
Report No. MA 1502-748

MAPECOAT I62 W
Outgassing VOC (23°C/90°C):
ISO-ACC_m Class -7.1 / tested

Flooring & Coating

Qualification Certificate

We hereby certify that the material stated above, provided by

Mapei S.p.A.
Milano, Italy

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number MA 1502-748.

MAPECOAT I62 W (Color Component A: transparent; Color Component B: white) was tested regarding outgassing at various temperatures according to VDI 2083-17. The tested material obtained the following classification:

Test temperatures	Family of contaminants	Specific emission rate [g/m ² s]	ISO-ACC _m Class (x)
23 °C / 73 °F	VOC	7.8 x 10 ⁻⁰⁸	-7.1
90 °C / 194 °F	Amines	not detectable	--
	Organophosphates	not detectable	--
	Siloxanes	2.6 x 10 ⁻⁰⁶	--
	Phthalates	not detectable	--

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, December 21, 2015

i. A. 
Project manager

DUPLICATE

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on www.tested-device.com.

For more CSM information, please visit www.ipa-csm.com.