



Fraunhofer

TESTED[®] DEVICE

Coroplast
Coroflex Hospital 4000
Report No. CO 1509-784

Biological Resistance

Qualification Certificate

This is to certify that the product mentioned above, provided by

Coroplast
Wuppertal, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number CO 1509-784.

The biological resistance of the cable sheathing material Coroflex Hospital 4000 (color: light gray) with regard to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	0	excellent
Bacteria (Procedure C)	0	excellent
Overall result	0	excellent

The classification is based on a worst-case consideration of Procedures A and C.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, March 20, 2016

on behalf of 
Frank Bürger, Project manager Fraunhofer IPA

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.
Further information:
www.tested-device.com

DUPLICATE