



Fraunhofer

TESTED[®] DEVICE

DAMPA ApS
Clip In ST 15 Tex
Report No. DA 1607-837

Biological Resistance

Qualification Certificate

This is to certify that the product mentioned above, provided by

DAMPA ApS
Tommerup, Denmark

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number DA 1607-837.

The biological resistance of the ceiling system Clip In 600 x 600 ST 15 Tex (color: RAL 9010) with regard to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	4	very weak
Bacteria (Procedure C)	1	very good
Overall result	4	very weak

The classification is based on a worst-case consideration of Procedures A and C. In the process, growth intensity was assessed according to the classification system used in ISO 846.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, November 7, 2016

on behalf of 
Frank Bürger, Project manager Fraunhofer IPA

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.
Further information:
www.tested-device.com

DUPLICATE