



# Fraunhofer

## TESTED<sup>®</sup> DEVICE

DAMPA ApS  
Clip In ST 15 Tex  
Report No. DA 1607-837

### Particle Emission

### Qualification Certificate

This is to certify that the product mentioned above, provided by

**DAMPA ApS**  
Tommerup, Denmark

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number DA 1607-837.

When operated under the specified test conditions, the ceiling system Clip In 600 x 600 ST 15 Tex (color: RAL 9010) is suitable for use in cleanrooms fulfilling the specifications of the following Air Cleanliness Class according to ISO 14644-1:

Test parameter(s)	Air Cleanliness Class
Structure-borne noise = approx. 5 to 50Hz	4
<b>Overall result</b>	<b>4</b>

According to ISO 14644-1 cleanrooms classes 1 to 5 have a high filter occupancy, with the result that large-surface ceiling systems cannot be used in some cases. Particle emission behavior may be influenced by the accessories used to install the ceiling system as well as by damage to the coated surfaces during the installation process. Therefore cleanroom suitability should be reassessed in the respective assembly situation.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

Stuttgart, November 7, 2016

on behalf of   
Frank Bürger, Project manager Fraunhofer IPA

DUPLICATE

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.  
Further information:  
[www.tested-device.com](http://www.tested-device.com)