



# Cleanroom<sup>®</sup> Suitable Materials

Roche Diagnostics GmbH  
Report No. RO 1608-852

MP2L stoneware tile  
Hydrogen Peroxide Absorption/  
Desorption: non-absorptive

## FLOORING & COATING

### Hydrogen Peroxide Absorption/Desorption

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Roche Diagnostics GmbH**  
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of  
Qualification with the report number RO 1608-852.

The hydrogen peroxide absorption/desorption of the MP2L  
stoneware tile was investigated at the stated test parameters,  
providing the following test result:

Ø k-value [min]	Standard deviation [min]	Classification
0	0.2	non-absorptive

- <5 min: ..... non-absorptive
- 5-15 min: ..... fast
- 15-60 min: ..... average
- >60 min: ..... slow
- Not determinable: ..... catalytic activity

Detailed information regarding specific product data such as date of  
manufacture, color, and serial number as well as test environment  
and parameters can be obtained from the CSM test report issued by  
the Fraunhofer-Gesellschaft.

Stuttgart, November 30, 2016

on behalf of   
Udo Gommel, Project manager Fraunhofer IPA

DUPLICATE

The validity of this  
certificate applies only to  
the mentioned product in  
this particular condition for  
a duration of

5 years.

Further information:

[www.tested-device.com](http://www.tested-device.com).

Please visit [www.ipa-csm.com](http://www.ipa-csm.com).