



Cleanroom[®] Suitable Materials

Roche Diagnostics GmbH
Report No. RO 1702-882

Powder coated wall panel
(smooth)

Riboflavin test: excellent

FLOORING & COATING

Riboflavin Test

Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

Roche Diagnostics GmbH
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1702-882.

Based on the VDMA information sheet »Riboflavin test for low-germ or sterile process technologies«, the ability to remove the fluorescent test contamination from the surface was tested by using a simple wiping process and ultra-pure water.

The examination of cleanability of the powder coated wall panel (color: white) was investigated according to VDMA information test sheet. The following test result could be provided:

Material tested	Classification
Powder coated wall panel (smooth)	excellent

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, May 5, 2017
Place, date of first document issued

--
Place, current date

on behalf of 
Udo Gommel, Project manager Fraunhofer IPA

The validity of this certificate applies only to the mentioned product in this particular condition for a duration of 5 years.

Further information:

www.tested-device.com.

Please visit www.ipa-csm.com.