



# Cleanroom<sup>®</sup> Suitable Materials

Roche Diagnostics GmbH  
Report No. RO 1702-883

MA Terrazzo LW standard  
(smooth)

Riboflavin Test: excellent

## FLOORING & COATING

### Riboflavin Test

### Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

**Roche Diagnostics GmbH**  
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1702-883.

The examination of cleanability of Roche Mannheim Terrazzo LW standard was investigated according to VDMA information test sheet. The following test result could be provided:

Material tested	Classification
Roche Mannheim Terrazzo LW standard (smooth)	<b>excellent</b>

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

RO 1702-883  
Report No. first document

--  
Report No. current document

Stuttgart, March 13, 2018  
Place, date of first document issued

--  
Place, current date

on behalf of   
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA