



Cleanroom[®] Suitable Materials

Roche Diagnostics GmbH
Report No. RO 1702-883

MA Terrazzo LW standard
Chemical Resistance: very good

FLOORING & COATING

Chemical Resistance

Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

Roche Diagnostics GmbH
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1702-883.

The chemical resistance tests on the Roche Mannheim Terrazzo LW standard are performed in accordance with ISO 2812-1. Therefore the damages according to ISO 4628-1 and VDI 2083 Part 17 have been transferred to the following classification:

Chemicals	Chemical resistance	Chemicals	Chemical resistance
Formalin 37 %	excellent	Phosphoric acid 30 %	excellent
Ammoniac 25 %	excellent	Hydrochloric acid 5 %	excellent
Isopropanol 100 %	excellent	Hydrogen peroxide 30 %	weak
Sulfuric acid 5 %	excellent	Sodium hydroxide 5 %	excellent
Peracetic acid 15 %	none	Sodium hypochlorite 5 %	good
Overall result	very good		

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

RO 1702-883
Report No. first document
--
Report No. current document

Stuttgart, March 13, 2018
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA