



Fraunhofer

TESTED[®] DEVICE

Roche Diagnostics GmbH
MA Terrazzo LW standard
Report No. RO 1702-883

Chemical Resistance

Qualification Certificate

This is to certify that the product mentioned above, provided by

Roche Diagnostics GmbH
Mannheim, Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number RO 1702-883.

The chemical resistance of the Roche Mannheim Terrazzo LW standard was classified according to ISO 4628-1 and VDI 2083 Part 17 with the following result:

Chemical resistance	
Ethanol 100 %	good
Purified water 100 %	excellent

The classification is based on a worst-case consideration. In the process, damage was assessed according to the classification system used in ISO 4628-1 and VDI 2083 Part 17:

- 0 = excellent
- 1 = very good
- 2 = good
- 3 = weak
- 4 = very weak
- 5 = none

RO 1702-883
Report No. first document

Stuttgart, March 21, 2018
Place, date of first document issued

--
Report No. current document

--
Place, current date

on behalf of 
Dr.-Ing. Frank Bürger, Project Manager Fraunhofer IPA

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

DUPLICATE