



Roche Diagnostics GmbH  
Report No. RO 1702-883

# Cleanroom<sup>®</sup> Suitable Materials

MA Terrazzo LW standard  
Biological Resistance: good

## FLOORING & COATING

### Biological Resistance

### Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

**Roche Diagnostics GmbH**  
Mannheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RO 1702-883.

The CSM classification of the Roche Mannheim Terrazzo LW standard according to biological resistance is based on a worst-case consideration of both procedures A and C. Therefore growth intensity according to ISO 846 and VDI 2083 Part 18 has been transferred to the following classification:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	2	good
Bacteria (Procedure C)	2	good
<b>Overall result</b>	<b>2</b>	<b>good</b>

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

RO 1702-883  
Report No. first document  
--  
Report No. current document

Stuttgart, March 13, 2018  
Place, date of first document issued  
--  
Place, current date

on behalf of   
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA