



Cleanroom[®] Suitable Materials

Sika Deutschland GmbH
Report No. SI 1709-952

Sikafloor-381 ECF
Particle (vs. PA6): ISO 3

FLOORING & COATING

Particle Emission

Qualification Certificate

We hereby certify that the material stated above, provided by

Sika Deutschland GmbH
Stuttgart, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number SI 1709-952.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Sikafloor-381 ECF (color: gray)	vs. PA6	ISO Class: 3
Reel-on-disc test Normal force 300N		

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found on the Fraunhofer IPA test report.

SI 1709-952
Report No. first document
--
Report No. current document

Stuttgart, March 7, 2018
Place, date of first document issued
--
Place, current date

on behalf of
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA

