



nora systems GmbH
Report No. NO 1711-969

Cleanroom® Suitable Materials

norament 926 grano
Biological Resistance: very good

FLOORING & COATING

Biological Resistance

Qualification Certificate

DUPLICATE

We hereby certify that the material stated above, provided by

nora systems GmbH
Weinheim, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NO 1711-969.

The CSM classification of norament 926 grano (color: 4882) according to biological resistance is based on a worst-case consideration of both procedures A and C. Therefore growth intensity according to ISO 846 and VDI 2083 Part 18 has been transferred to the following classification:

Biological resistance	Growth intensity	Classification
Fungi (Procedure A)	1	very good
Bacteria (Procedure C)	1	very good
Overall result	1	very good

This document only applies to the named product in its original state and is valid for a period of 5 years from the date the first document was issued. The document can be verified under www.tested-device.com.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

NO 1711-969
Report No. first document
--
Report No. current document

Stuttgart, February 28, 2018
Place, date of first document issued
--
Place, current date

on behalf of 
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA